

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Changan Group Co., Ltd.
No.288 Wei17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang,
China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Un= 230/400V~ (1P), 400V~ (2P,3P, 4P)
In= 1, 2, 3, 4, 5A (B- and C-type)
In= 6, 10, 16, 20, 25, 32, 40, 50, 63A (B-, C- and D-type)
B-, C- and D-type, Icn= Ics= 4500A, 50/60Hz

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

DZ47-63S

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

200500244SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature: *Leif Söderlund*

Date: 07 July, 2020

Leif Söderlund

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

SE-101694

Factories

Additional information (if necessary)

Date: 07 July, 2020

Signature: *Leif Söderlund*