

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50501324

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
Y.F

Unser Zeichen *Our Reference*
01-DY-CN21GDAS 001

Ausstellungsdatum
13.05.2021

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Changan Group Co., Ltd.
NO.288 Wei17th Road,
Yueqing Economic Development Zone,
Yueqing, Wenzhou
Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*

Changan Group Co., Ltd.
NO.288 Wei17th Road,
Yueqing Economic Development Zone,
Yueqing, Wenzhou
Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60898-1:2019

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product (Product Identification)

Lizenzentgelte - Einheit

License Fee - Unit

Miniature circuit breaker (MCB)

Type Designation : 1) CABa-63 ; 2) CABa-63H ;
a=2,6,X
Instantaneous Tripping
Current : C/D Type
Rated Operation Voltage (Ue) : 230/400VAC; (1P)
400VAC (2P/3P/4P), 50Hz
Rated Current (In) : 6/10/16/20/25/32/40/50/63A
Rated Short-circuit
Capacity (Icn) : 1) 4,5kA; 2) 6,0kA
Rated Service Short-circuit
Capacity (Ics) : Same as Icn
Rated Impulse Withstand
Voltage (Uimp) : 4,0kV
Rated Insulation Voltage : 690V
Suitability of Isolation : Yes
Pollution Degree : 2

8

8

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Kenny Shi