

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50329594

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
W.Z.F.

Unser Zeichen *Our Reference*
01-ZWC-15093144 001

Ausstellungsdatum
27.01.2016

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*
Changan Group Co., Ltd.
NO.288 Wei17th Road,
Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province
P. R. China

Fertigungsstätte *Manufacturing Plant*
Changan Group Co., Ltd.
NO.288 Wei17th Road,
Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60947-2:2006+A1+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Circuit Breaker (Moulded Case Circuit Breaker)

Type Designation : 1) CAM1-25QL ; 2) CAM1-250M ;
3) CAM1-250H

8

Utilization category : A
Reference Temperature : +40°C or +30°C
Number of Poles : 2P/3P/3P+N/4P
Rated Operation Voltage (Ue): AC 400; 50/60Hz
Rated Current (In) : 100A, 250A, 160A, 25A, 180A,
200A, 225A, 250A
Breaking Capacity (Icu) : 1) 35kA; 2) 50kA; 3) 65kA
Rated Ultimate Short-circuit
Breaking Capacity (Ics) : 1) 25kA; 2) 30kA; 3) 50kA
Rated Service Short-circuit
Rated Impulse Withstand
Voltage (Uimp) : 8,0kV
Rated Insulation Voltage (Ui): 800V

Continued on page 0002

8

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Jie Zhang