

Test Verification of Conformity

Verification Number: 210402198SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the regulation(s) listed on this verification at the time the tests were carried out. Other standards and Regulations may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.



Once compliance with all product relevant UK CA mark regulations are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	CHANGAN GROUP CO., LTD. No. 288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang Province, P.R.China
Manufacturer site:	Same as applicant
Product Description:	Low-voltage switchgear and controlgear; AC contactors
Ratings & Principle Characteristics:	See Appendix page
Models/Type References:	CC1-115, CC1-1154, CC1-150, CC1-1504, CC1-185, CC1-1854, CC1-225, CC1-2254, CC1-265, CC1-2654, CC1-330, CC1-3304, CC1-400, CC1-4004
Brand Name:	CHANA [®]
Relevant Standards/Regulations:	BS EN 60947-4-1:2010+A1:2012 Electrical Equipment (Safety) Regulations 2016
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2018-05-24 to 2018-07-31
Test Report Number(s):	180502258SHA-001, -002, -003



Signature

Name: Oliver Wei
Position: Manager
Date: 20 May 2021

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 210402198SHA-V1.

Rating and principal characteristics:

Model: CC1-115

Ue= 415V~, AC-3: Ie= 115A, AC-4: Ie= 52A, 3P
Ith= 200A, Ir= 10kA, Iq= 10kA, Ui= 690V, Uimp= 6kV

Model: CC1-1154

Ue= 415V~, AC-3: Ie= 115A, AC-4: Ie= 52A, 4P
Ith= 200A, Ir= 10kA, Iq= 10kA, Ui= 690V, Uimp= 6kV

Model: CC1-150

Ue= 415V~, AC-3: Ie= 150A, AC-4: Ie= 60A, 3P
Ith= 200A, Ir= 10kA, Iq= 10kA, Ui= 690V, Uimp= 6kV

Model: CC1-1504

Ue= 415V~, AC-3: Ie= 150A, AC-4: Ie= 60A, 4P
Ith= 200A, Ir= 10kA, Iq= 10kA, Ui= 690V, Uimp= 6kV
Control circuit: Us= 230, 415V~

Model: CC1-185

Ue= 415V~, AC-3: Ie= 185A, AC-4: Ie= 79A, 3P
Ith= 275A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Model: CC1-1854

Ue= 415V~, AC-3: Ie= 185A, AC-4: Ie= 79A, 4P
Ith= 275A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Model: CC1-225

Ue= 415V~, AC-3: Ie= 225A, AC-4: Ie= 86A, 3P
Ith= 275A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Model: CC1-2254

Ue= 415V~, AC-3: Ie= 225A, AC-4: Ie= 86A, 4P
Ith= 275A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Model: CC1-265

Ue= 415V~, AC-3: Ie= 265A, AC-4: Ie= 105A, 3P
Ith= 315A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Model: CC1-2654

Ue= 415V~, AC-3: Ie= 265A, AC-4: Ie= 105A, 4P
Ith= 315A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV
Control circuit: Us= 230, 415V~

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 210402198SHA-V1.

Rating and principal characteristics:

Model: CC1-330

Ue= 415V~, AC-3: Ie= 330A, AC-4: Ie= 117A, 3P

Ith= 380A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Model: CC1-3304

Ue= 415V~, AC-3: Ie= 330A, AC-4: Ie= 117A, 4P

Ith= 380A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Model: CC1-400

Ue= 415V~, AC-3: Ie= 400A, AC-4: Ie= 138A, 3P

Ith= 460A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Model: CC1-4004

Ue= 415V~, AC-3: Ie= 400A, AC-4: Ie= 138A, 4P

Ith= 460A, Ir= 18kA, Iq= 18kA, Ui= 690V, Uimp= 6kV

Control circuit: Us= 230, 415V~



Signature

Name: Oliver Wei

Position: Manager

Date: 20 May 2021

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.